Australian/New Zealand Standard[™]

Effects of current on human beings and livestock

Part 1: General aspects





AS/NZS 60479.1:2010

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee EL-001, Wiring Rules. It was approved on behalf of the Council of Standards Australia on 14 April 2010 and on behalf of the Council of Standards New Zealand on 23 April 2010.

This Standard was published on 11 May 2010.

The following are represented on Committee EL-001:

Association of Consulting Engineers Australia Australian Building Codes Board Australian Industry Group Communications, Electrical and Plumbing Union Consumers' Federation of Australia Electrical and Communications Association (Queensland) Electrical Contractors Association of New Zealand **Electrical Regulatory Authorities Council** Electrical Safety Organisation (New Zealand) ElectroComms and Energy Utilities Industries Skills Council Energy Networks Australia **Engineers** Australia Institute of Electrical Inspectors Ministry of Economic Development (New Zealand) National Electrical and Communications Association New Zealand Council of Elders New Zealand Electrical Institute New Zealand Manufacturers and Exporters Association **Telstra Corporation Limited**

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR AS/NZS 60479.1.

Australian/New Zealand Standard[™]

Effects of current on human beings and livestock

Part 1: General aspects

Originated as part of MP 30—1976. Previous edition AS 3859—1991. Jointly revised and redesignated in part as AS/NZS 60479.1:2002. Second edition 2010.

COPYRIGHT

© Standards Australia/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Jointly published by Standards Australia, GPO Box 476, Sydney, NSW 2001 and Standards New Zealand, Private Bag 2439, Wellington 6140

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee EL-001, Wiring Rules.

The objective of this Standard is to provide basic guidance on the effects of shock current on human beings and livestock, for use in the establishment of electrical safety requirements.

This Standard is identical with, and has been reproduced from IEC/TR 60479-1, Ed. 4.0(2005), *Effects of current on human beings and livestock – Part 1: General aspects.*

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this technical specification' should read 'this Australian/New Zealand Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.

The terms 'normative' and 'informative' are used to define the application of the annex to which it applies. A normative annex is an integral part of a Standard, whereas an informative annex is only for information and guidance.

CONTENTS

Page

INTRODUCTION			
1	Scope		1
2	Normative references		1
3	Terms and definitions		2
	3.1	General definitions	2
	3.2	Effects of sinusoidal alternating current in the range 15 Hz to 100 Hz	3
	3.3	Effects of direct current	3
4	Elect	lectrical impedance of the human body	
	4.1	Internal impedance of the human body (Z_{i})	4
	4.2	Impedance of the skin (Z_s)	4
	4.3	Total impedance of the human body (Z_{T})	5
	4.4	Factors affecting initial resistance of the human body (R_0)	5
	4.5	Values of the total impedance of the human body (Z_{T})	5
	4.6	Value of the initial resistance of the human body (R_0)	. 13
5	Effec	ts of sinusoidal alternating current in the range of 15 Hz to 100 Hz	. 13
	5.1	Threshold of perception	. 13
	5.2	Threshold of reaction	. 13
	5.3	Immobilization	. 13
	5.4	Threshold of let-go	. 13
	5.5	Threshold of ventricular fibrillation	. 14
	5.6	Other effects related to electric shocks	. 14
	5.7	Effects of current on the skin	. 15
	5.8	Description of time/current zones (see Figure 20)	. 15
	5.9	Application of heart-current factor (F)	. 16
6	Effects of direct current		. 16
	6.1	Threshold of perception and threshold of reaction	. 16
	6.2	Threshold of immobilization and threshold of let-go	. 17
	6.3	Threshold of ventricular fibrillation	. 17
	6.4	Other effects of current	. 17
	6.5	Description of time/current zones (see Figure 22)	. 18
	6.6	Heart factor	. 18
Annexes			
Annex A (normative) Measurements of the total body impedances Z_T made on living human beings and on corpses and the statistical analysis of the results			
Annex B (normative) Influence of frequency on the total body impedance (Z_T)			. 41
An	Annex C (normative) Total body resistance (R_T) for direct current		
An	Annex D (informative) Examples of calculations of Z _T		
Bibliography			

INTRODUCTION

This technical specification provides basic guidance on the effects of shock current on human beings and livestock, for use in the establishment of electrical safety requirements.

In order to avoid errors in the interpretation of this specification, it must be emphasized that the data given herein is mainly based on experiments with animals as well as on information available from clinical observations. Only a few experiments with shock currents of short duration have been carried out on living human beings.

On the evidence available, mostly from animal research, the values are so conservative that the standard applies to persons of normal physiological conditions including children, irrespective of age and weight.

There are, however, other aspects to be taken into account, such as probability of faults, probability of contact with live or faulty parts, ratio between touch voltage and fault voltage, experience gained, technical feasibilities, and economics. These parameters have to be considered carefully when fixing safety requirements, for example, operating characteristics of protective devices for electrical installations.

The form of the specification as has been adopted summarizes results so far achieved which are being used by technical committee 64 as a basis for fixing requirements for protection against shock. These results are considered important enough to justify an IEC publication which may serve as a guide to other IEC committees and countries having need of such information.

This technical specification applies to the threshold of ventricular fibrillation which is the main cause of deaths by electric current. The analysis of results of recent research work on cardiac physiology and on the fibrillation threshold, taken together, has made it possible to better appreciate the influence of the main physical parameters and, especially, of the duration of the current flow.

IEC 60479-1 contains information about body impedance and body current thresholds for various physiological effects. This information can be combined to derive estimates of a.c. and d.c. touch voltage thresholds for certain body current pathways, contact moisture conditions, and skin contact areas. Information about touch voltage thresholds for physiological effects is contained in the IEC 61201.

This specification refers specifically to the effects of electric current. When an assessment of the harmful effects of any event on human beings and livestock is being made, other nonelectric phenomena, including falls, heat, fire, or others should be taken into account. These matters are beyond the scope of this specification, but may be extremely serious in their own right.

Recent research work has also been conducted on the other physical accident parameters, especially the waveform and frequency of the current and the impedance of the human body. This fourth revision of IEC 60479-1 should be viewed as the logical development and evolution of the third edition.

Clause 2 of IEC 60479-1 (third edition) on the impedance of the human body contained little information on the dependence of the impedance on the surface area of contact and then only for dry conditions.

Therefore measurements were carried out on 10 persons using medium and small surface areas of contact in dry, water-wet and saltwater-wet conditions, current path hand to hand, at a touch voltage of 25 V a.c. 50 Hz. The impedance values for a percentile rank of 5 %, 50 % and 95 % have been calculated from these measurements.

Due to unpleasant sensations and the possibility of inherent danger, measurements using large surface areas of contact (order of magnitude 10 000 mm²) in dry, water-wet and saltwater-wet conditions and with medium and small surface areas of contact (order of magnitude 1 000 mm² and 100 mm²) in dry condition at touch voltages from 25 V up to and including 200 V a.c. have only been carried out on one person. By the use of deviation factors it was nevertheless possible to derive values of the total body impedance Z_T for a percentile rank of 5 %, 50 % and 95 % of a population of persons. With the same one person measurements were also made with still smaller surface areas of contact (10 mm² and 1 mm²) and between fingertips.

For the calculation of total body impedance Z_T for a percentile rank of 5 %, 50 % and 95 % of a population of persons for large surface areas of contact for touch voltages above 200 V up to 700 V and higher up to the asymptotic values the method to adapt values of Z_T measured on corpses to those of persons used for the second edition of IEC 60479-1 was improved by taking account of the different temperature of the corpses during measurements and the temperature of 37 °C for persons.

The present state of knowledge of a.c. impedance Z_T of the human body for large, medium and small surface areas of contact in dry, water-wet and salt-water-wet conditions and of the d.c.-resistance R_T of the human body for large areas of contact in dry conditions are presented.

It should be mentioned that the thresholds as order of magnitude are valid for all persons (men, women and children) independent of their state of health. Often concerns are expressed in that respect but if the background of such objections is examined it is found that such objections represent just opinions without experimental evidence. Some measurements indicate that the thresholds of perception and let-go for women are lower than for men. This may also be the case for children.

Furthermore in Clause 5 a heart-current factor F for the current path foot to foot has been introduced. This is important for electrical risks caused by step voltages.