

Vehicular Natural Gas Fuel Systems Code

2019



IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

NOTICE AND DISCLAIMER OF LIABILITY CONCERNING THE USE OF NFPA STANDARDS

NFPA® codes, standards, recommended practices, and guides ("NFPA Standards"), of which the document contained herein is one, are developed through a consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on fire and other safety issues. While the NFPA administers the process and establishes rules to promote fairness in the development of consensus, it does not independently test, evaluate, or verify the accuracy of any information or the soundness of any judgments contained in NFPA Standards.

The NFPA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on NFPA Standards. The NFPA also makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

In issuing and making NFPA Standards available, the NFPA is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the NFPA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The NFPA has no power, nor does it undertake, to police or enforce compliance with the contents of NFPA Standards. Nor does the NFPA list, certify, test, or inspect products, designs, or installations for compliance with this document. Any certification or other statement of compliance with the requirements of this document shall not be attributable to the NFPA and is solely the responsibility of the certifier or maker of the statement.

REVISION SYMBOLS IDENTIFYING CHANGES FROM THE PREVIOUS EDITION

Text revisions are shaded. A Δ before a section number indicates that words within that section were deleted and a Δ to the left of a table or figure number indicates a revision to an existing table or figure. When a chapter was heavily revised, the entire chapter is marked throughout with the Δ symbol. Where one or more sections were deleted, a • is placed between the remaining sections. Chapters, annexes, sections, figures, and tables that are new are indicated with an N.

Note that these indicators are a guide. Rearrangement of sections may not be captured in the markup, but users can view complete revision details in the First and Second Draft Reports located in the archived revision information section of each code at www.nfpa.org/docinfo. Any subsequent changes from the NFPA Technical Meeting, Tentative Interim Amendments, and Errata are also located there.



ALERT: THIS STANDARD HAS BEEN MODIFIED BY A TIA OR ERRATA

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that NFPA Standards may be amended from time to time through the issuance of a Tentative Interim Amendment (TIA) or corrected by Errata. An official NFPA Standard at any point in time consists of the current edition of the document together with any TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, go to www.nfpa.org/docinfo to choose from the list of NFPA Standards or use the search feature to select the NFPA Standard number (e.g., NFPA 13). The document information page provides up-todate document-specific information as well as postings of all existing TIAs and Errata. It also includes the option to register for an "Alert" feature to receive an automatic email notification when new updates and other information are posted regarding the document.

ISBN: 978-145592145-4 (PDF) ISBN: 978-14559221<u>5-4 (eBook)</u>

ADDITIONAL IMPORTANT NOTICES AND DISCLAIMERS CONCERNING NFPA® STANDARDS

Updating of NFPA Standards

Users of NFPA codes, standards, recommended practices, and guides ("NFPA Standards") should be aware that these documents may be superseded at any time by the issuance of a new edition, may be amended with the issuance of Tentative Interim Amendments (TIAs), or be corrected by Errata. It is intended that through regular revisions and amendments, participants in the NFPA standards development process consider the then-current and available information on incidents, materials, technologies, innovations, and methods as these develop over time and that NFPA Standards reflect this consideration. Therefore, any previous edition of this document no longer represents the current NFPA Standard on the subject matter addressed. NFPA encourages the use of the most current edition of any NFPA Standard [as it may be amended by TIA(s) or Errata] to take advantage of current experience and understanding. An official NFPA Standard at any point in time consists of the current edition of the document, including any issued TIAs and Errata then in effect.

To determine whether an NFPA Standard has been amended through the issuance of TIAs or corrected by Errata, visit the "Codes & Standards" section at www.nfpa.org.

Interpretations of NFPA Standards

A statement, written or oral, that is not processed in accordance with Section 6 of the Regulations Governing the Development of NFPA Standards shall not be considered the official position of NFPA or any of its Committees and shall not be considered to be, nor be relied upon as, a Formal Interpretation.

Patents

The NFPA does not take any position with respect to the validity of any patent rights referenced in, related to, or asserted in connection with an NFPA Standard. The users of NFPA Standards bear the sole responsibility for determining the validity of any such patent rights, as well as the risk of infringement of such rights, and the NFPA disclaims liability for the infringement of any patent resulting from the use of or reliance on NFPA Standards.

NFPA adheres to the policy of the American National Standards Institute (ANSI) regarding the inclusion of patents in American National Standards ("the ANSI Patent Policy"), and hereby gives the following notice pursuant to that policy:

NOTICE: The user's attention is called to the possibility that compliance with an NFPA Standard may require use of an invention covered by patent rights. NFPA takes no position as to the validity of any such patent rights or as to whether such patent rights constitute or include essential patent claims under the ANSI Patent Policy. If, in connection with the ANSI Patent Policy, a patent holder has filed a statement of willingness to grant licenses under these rights on reasonable and nondiscriminatory terms and conditions to applicants desiring to obtain such a license, copies of such filed statements can be obtained, on request, from NFPA. For further information, contact the NFPA at the address listed below.

Law and Regulations

Users of NFPA Standards should consult applicable federal, state, and local laws and regulations. NFPA does not, by the publication of its codes, standards, recommended practices, and guides, intend to urge action that is not in compliance with applicable laws, and these documents may not be construed as doing so.

Copyrights

NFPA Standards are copyrighted. They are made available for a wide variety of both public and private uses. These include both use, by reference, in laws and regulations, and use in private self-regulation, standardization, and the promotion of safe practices and methods. By making these documents available for use and adoption by public authorities and private users, the NFPA does not waive any rights in copyright to these documents.

Use of NFPA Standards for regulatory purposes should be accomplished through adoption by reference. The term "adoption by reference" means the citing of title, edition, and publishing information only. Any deletions, additions, and changes desired by the adopting authority should be noted separately in the adopting instrument. In order to assist NFPA in following the uses made of its documents, adopting authorities are requested to notify the NFPA (Attention: Secretary, Standards Council) in writing of such use. For technical assistance and questions concerning adoption of NFPA Standards, contact NFPA at the address below.

For Further Information

All questions or other communications relating to NFPA Standards and all requests for information on NFPA procedures governing its codes and standards development process, including information on the procedures for requesting Formal Interpretations, for proposing Tentative Interim Amendments, and for proposing revisions to NFPA standards during regular revision cycles, should be sent to NFPA headquarters, addressed to the attention of the Secretary, Standards Council, NFPA, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101; email: stds_admin@nfpa.org.

For more information about NFPA, visit the NFPA website at www.nfpa.org. All NFPA codes and standards can be viewed at no cost at www.nfpa.org/docinfo.

NFPA[®] 52

Vehicular Natural Gas Fuel Systems Code

2019 Edition

This edition of NFPA 52, *Vehicular Natural Gas Fuel Systems Code*, was prepared by the Technical Committee on Vehicular Alternative Fuel Systems. It was issued by the Standards Council on November 5, 2018, with an effective date of November 25, 2018, and supersedes all previous editions.

This document has been amended by one or more Tentative Interim Amendments (TIAs) and/or Errata. See "Codes & Standards" at www.nfpa.org for more information.

This edition of NFPA 52 was approved as an American National Standard on November 25, 2018.

Origin and Development of NFPA 52

While compressed natural gas (CNG) vehicles have been used extensively in other countries since the late 1940s, it was not until the late 1970s that their use in the United States became extensive enough to warrant preparation of a national standard.

Between 1980 and 1982, a committee of the American Gas Association (AGA) developed a draft of a fire safety standard for vehicular fuel systems. This was based on existing worldwide standards and current U.S. practice.

In late 1981, the AGA petitioned the NFPA to establish a technical committee project on the subject. The normal NFPA solicitation of comments revealed sufficient response from various interested parties, and the Committee on Compressed Natural Gas Vehicular Fuel Systems was established by the Standards Council in July 1982.

The first edition of NFPA 52, *Standard for Compressed Natural Gas (CNG) Vehicular Fuel Systems*, was issued in 1984, and it was revised in 1988, 1992, 1995, and 1998.

The 2002 edition of NFPA 52 contained minor revisions, most of these in the chapter on engine fuel systems. There also were some changes made to comply with the NFPA *Manual of Style* for technical committee documents. The most significant of these were reordering of chapters and numbering of definitions.

The 2006 edition of NFPA 52 was a complete revision. NFPA 57, *LNG Vehicular Fuel Systems Code*, was incorporated into NFPA 52. Additionally, the scope of the committee was expanded to include hydrogen, and new chapters were added that addressed general gaseous hydrogen requirements and equipment qualifications; service and maintenance of gaseous hydrogen engine fuel systems; gaseous hydrogen compression, gas processing, storage, and dispensing systems; and liquefied hydrogen fueling facilities.

The 2010 edition of NFPA 52 revised the committee scope so that it better coordinated with the responsibilities of NFPA 55, *Compressed Gases and Cryogenic Fluids Code*, with regard to hydrogen storage systems. A large number of changes were also made to the chapters concerning hydrogen to update to current material in NFPA documents, the *Manual of Style for NFPA Technical Committee Documents*, and acceptable performance criteria.

Paragraphs extracted from NFPA 55 were shown with the extract reference in brackets [] at the end of the paragraph. In some cases, modifications were made to the extracted text to use terminology appropriate for this standard, such as the term *cryogenic fluid* instead of *compressed gas*. In those instances, brackets encased the modified terms.

The 2013 edition removed the requirements for hydrogen systems, the responsibility for which were transferred to NFPA 2, *Hydrogen Technologies Code*. A chapter on general fueling requirements was added, and changes were made to the onboard gas detection requirements for LNG-fueled vehicles. The installation requirements for ASME Tanks for LNG were updated to coordinate with NFPA 59A, *Standard for the Production, Storage, and Handling of Liquefied Natural Gas (LNG)*.

NFPA and National Fire Protection Association are registered trademarks of the National Fire Protection Association, Quincy, Massachusetts 02169.

The 2016 edition was completely reorganized for easier access to requirements. The title of the document was changed from *Vehicular Gaseous Fuel Systems Code* to *Vehicular Natural Gas Fuel Systems Code* to coordinate with the removal of hydrogen systems from the scope of the document in 2013. New and revised definitions harmonized the code with the new CSA Group NGV 5.1 standard, *Residential Fueling Appliances*. Most notably, a new definition for *residential fueling appliances* was added and the definition for *vehicle fueling appliances* was revised.

For the 2019 edition, text reorganization and additions have been made to address vehicle fueling applications (VFAs). A new chapter was added for nonresidential CNG fueling applications. Several terms have been added and updated to align with current definitions and VFA updates to the document. Examples are changing the term *Qualified Engineer* to *Qualified Person* and adding the definition of the term *Contiguous Building Volume* to Chapter 3. Sections of the residential CNG Fueling chapter were removed because they were part of the certification of appliances covered in CSA Group NGV 5.1, *Residential Fueling Appliances*.

Technical Committee on Vehicular Alternative Fuel Systems

Stephen V. Abernathy, Chair Consultant, SC [SE]

Jim Ames, Ameswest Technical Services, UT [IM]
Michael Battagllia, CNG-ONE, LLC, OH [IM]
Dan Bowerson, NGVAmerica, MI [M]
Julie Cairns, CSA Group, OH [RT]
Matt T. Creedon, Pacific Gas & Electric Company, CA [U]
Denis C. K. Ding, Clean Energy Fuels Corporation, CA [M]
Rob Early, Compressed Gas Association, NY [M]
Thomas J. Forsythe, JENSEN HUGHES, CA [SE] Rep. JENSEN HUGHES
Mike Gust, Quantum Fuel Systems, CA [U]
Alan D. Hatfield, Braemar Engineering, TX [SE]
John Jordan, Agility Fuel Systems, MN [M]
Zach Klein, McNeilus Truck And Manufacturing, MN [M]
Quon Y. Kwan, U.S. Department of Transportation, DC [E] Rep. U.S. Department of Transportation Reid B. Larson, Chart Industries, MN [M]
Rick Long, Petroleum Equipment Institute, OK [IM]
Michael W. Mackey, GP Strategies Corporation, CA [SE]
Timothy E. Meyers, U.S. Coast Guard, DC [E]
Nancy C. Pehrson, CenterPoint Energy, Inc., MN [U]
April Dawn Richardson, Railroad Commission of Texas, TX [E]
Joel E. Sipe, Exponent, Inc., CA [SE]
Glen E. Smith, Union Pacific Railroad, NE [SE]
Rep. American Railway Engineering & Maintenance-of-Way
Assn.
E. Michael Steele, Steele Consulting, CA [M]
Rep. Society of Automotive Engineers
Kent Whiting, BlackPak Inc., CA [M]
Ted Williams, American Gas Assocication, DC [U]
Rep. American Gas Association

Alternates

Richard A. Craig, Compressed Gas Association, VA [M] (Alt. to Rob Early)
Andrew Gibbons, U.S. Coast Guard, DC [E] (Alt. to Timothy E. Meyers)

Susan Bershad, NFPA Staff Liaison

James P. Lewis, Jim Lewis LNG Expertise, TX [SE] (Alt. to Michael W. Mackey) Timothy Lester Morse, Exponent, MA [SE] (Alt. to Joel E. Sipe)

This list represents the membership at the time the Committee was balloted on the final text of this edition. Since that time, changes in the membership may have occurred. A key to classifications is found at the back of the document.

NOTE: Membership on a committee shall not in and of itself constitute an endorsement of the Association or any document developed by the committee on which the member serves.

Committee Scope: This Committee shall have primary responsibility for documents on fire and explosion hazards associated with compressed natural gas (CNG), liquefied natural gas (LNG) engine fuel systems, on vehicles of all types and for refueling stations and associated storage.

The Committee shall coordinate its documents with the Committee on the National Fuel Gas Code with respect to natural gas piping within the scope of that Committee; with the Committees on Industrial Trucks, Fire Safety for Recreational Vehicles, and Marine Fire Protection with respect to engine fuel systems and refueling stations within their scopes; and the Liquefied Natural Gas Committee with respect to storage of LNG within its scope.

Contents

Chapter	1 Administration	52– 6
$1.\bar{1}$	Scope	52– 6
1.2	Purpose.	52– 6
1.3	Retroactivity.	52– 6
1.4	Alternate Provisions.	52– 6
1.5	Training	52 - 7
1.6	Units	59_ 7
1.0	Enforcement	52-7 59-7
1.7	Linorcement.	54-7
Chapter	2 Referenced Publications	52 – 7
2.1	General.	52 – 7
2.2	NFPA Publications.	52 – 7
2.3	Other Publications	52-7
9.4	References for Extracts in Mandatory Sections	5 <u>7</u> 8
		01 0
Chapter	3 Definitions	52– 8
3.1	General.	52– 8
3.2	NFPA Official Definitions.	52– 8
3.3	General Definitions.	52– 9
Chapter	4 Facility Management	52– 12
4.1	General	52– 12
4.2	Building Construction Materials.	52– 12
4.3	Qualifications.	52– 13
4.4	Equipment Security.	52– 13
4.5	Operations and Maintenance.	52– 13
4.6	CNG Training.	52– 15
4.7	LNG Training.	52– 15
4.8	Special Hazard Requirements.	52– 15
	1	
Chapter	5 Facility Fire Protection	52– 16
5.1	General	52– 16
5.2	CNG Supplemental Requirements.	52– 16
5.3	LNG Supplemental Requirements.	52– 17
Chapter	6 Facility Gas Detection, Alarm, and	
	Emergency Shutdown Systems	52– 18
6.1	General	52– 18
6.2	CNG Supplemental Requirements.	52– 18
6.3	LNG Supplemental Requirements.	52– 18
~		FO 10
Chapter	7 Fuel Quality	52 – 18
7.1	General.	52 – 18
7.2	CNG.	52– 18
7.3	LNG. (Reserved)	52– 18
Chantar	8 Eacility Equipment	59 10
	8 Facinity Equipment	54-10 F9 10
0.1	Application	54-18 59 10
0.2	Application.	54-10 59 10
8.3	General.	52-18 59 10
8.4	CNG Systems.	52 – 19
Chanter	9 Outdoor Storage	59 _ 99
	Scope	52-22 59-99
0.9	Concerel (Reserved)	54-22 59 99
9.4	CNC Supplemental Requirements	52-22
9.9 Q /	LNC Supplemental Requirements	5 <u>4</u> - 44
5.4	ило заррешения кечинешень	34 - 44
Chapter	10 Indoor Storage	52– 23
10.1	Scope.	52 - 23
10.9	General. (Reserved)	52 - 23
10.3	CNG Supplemental Requirements	52 93
10.4	LNG Supplemental Requirements	52 95
± 0. 1		54-45

	11 CNG Fueling	52 – 25
11.1	Application.	52 -25
11.2	General.	52 – 25
11.3	CNG Dispensing.	52 – 25
	1 0	
Chapter	12 Residential CNG Fueling Appliances	52 – 31
12.1	Application.	52 – 31
12.2	System Component Qualifications	52 – 32
12.3	General Safety Requirements.	52 - 32
12.4	Installation.	52-32
12.5	Installation of PRVs.	52-32
12.0	Processing Regulation	52- 32 59 99
14.7	Piping and Hase	54-54
12.0	Testing	52 - 32 59 - 39
19.10	Operation	52 - 32 59 - 39
12.10	Maintenance and Inspection	52 - 32 59 - 39
14.11	Maintenance and inspection.	34 - 34
Chapter	13 Nonresidential CNG Fueling Appliances	52 – 33
13.1	General.	52– 33
13.2	Installation.	52– 34
13.3	Operation	52– 34
13.4	Maintenance and Inspection	52– 34
~		
Chapter	14 LNG Fueling	52 - 34
14.1	Application.	52 - 34
14.2	LNC Dimension	52- 34 59 94
14.5	LNG Dispensing.	52- 34 59 40
14.4	LING Storage.	52-40 59-41
14.5	riping systems and components.	54-41
Chapter	15 Automotive Equipment (Onboard)	52– 41
15.1	Scope.	52– 41
15.2	Application	52– 41
15.3	General	52– 41
15.4	CNG Supplemental Requirements.	52– 42
15.5	LNG Supplemental Requirements.	52– 43
Chaptor		
Chapter	16 Automotive Fuel and Safety Systems	
	16 Automotive Fuel and Safety Systems (Ophcard)	59 _ 45
16.1	16 Automotive Fuel and Safety Systems (Onboard)	52 – 45 52 – 45
16.1 16.2	16 Automotive Fuel and Safety Systems (Onboard) Application	52 – 45 52 – 45 52 – 45
$16.1 \\ 16.2 \\ 16.3$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems	52 – 45 52 – 45 52 – 45 52 – 45
$16.1 \\ 16.2 \\ 16.3 \\ 16.4$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems.	52 – 45 52 – 45 52 – 45 52 – 47 52 – 52
$16.1 \\ 16.2 \\ 16.3 \\ 16.4$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems.	52– 45 52– 45 52– 45 52– 47 52– 52
16.1 16.2 16.3 16.4 Chapter	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks	52– 45 52– 45 52– 45 52– 45 52– 47 52– 52
16.1 16.2 16.3 16.4 Chapter	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG	52– 45 52– 45 52– 45 52– 47 52– 52 52– 52
16.1 16.2 16.3 16.4 Chapter 17.1	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application.	52 - 45 52 - 45 52 - 45 52 - 47 52 - 52 52 - 52 52 - 56 52 - 56
16.1 16.2 16.3 16.4 Chapter 17.1 17.2	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General.	52 - 45 52 - 45 52 - 45 52 - 47 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General. Containers.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56 52 - 56
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Containers. Container Foundations and Supports. Installation Supports.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56 52 - 56 52 - 57
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. General.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 52 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57
$\begin{array}{c} 16.1 \\ 16.2 \\ 16.3 \\ 16.4 \end{array}$ Chapter $\begin{array}{c} 17.1 \\ 17.2 \\ 17.3 \\ 17.4 \\ 17.5 \\ 17.6 \\ 17.6 \end{array}$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General. Containers. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Total	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57 52 - 57
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5 17.6 17.7	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Environment Social Systems.	52 – 45 52 – 45 52 – 45 52 – 45 52 – 52 52 – 56 52 – 56 52 – 56 52 – 56 52 – 57 52 – 57 52 – 57 52 – 58
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5 17.6 17.7 17.8	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57 52 - 57 52 - 57 52 - 58 52 - 58 52 - 58 52 - 58
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5 17.6 17.7 17.8 17.9	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers. Containers. Containers.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57 52 - 57 52 - 57 52 - 58 52 - 58 53 - 58 53 - 58 53 - 58 55 -
$\begin{array}{c} 16.1\\ 16.2\\ 16.3\\ 16.4 \end{array}$ Chapter $\begin{array}{c} 17.1\\ 17.2\\ 17.3\\ 17.4\\ 17.5\\ 17.6\\ 17.7\\ 17.8\\ 17.9\\ 17.10\\ 17.10\\ 17.11 \end{array}$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers. Piping. Container Instrumentation.	52 – 45 52 – 45 52 – 45 52 – 45 52 – 52 52 – 56 52 – 56 52 – 56 52 – 56 52 – 57 52 – 57 52 – 57 52 – 58 52 – 58 52 – 58 52 – 59 52 –
$\begin{array}{c} 16.1 \\ 16.2 \\ 16.3 \\ 16.4 \end{array}$ Chapter $\begin{array}{c} 17.1 \\ 17.2 \\ 17.3 \\ 17.4 \\ 17.5 \\ 17.6 \\ 17.7 \\ 17.8 \\ 17.9 \\ 17.10 \\ 17.11 \end{array}$	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers. Piping. Container Instrumentation. Pressure Gauging and Control. Pressure Gauging and Control.	52 – 45 52 – 45 52 – 45 52 – 45 52 – 52 52 – 56 52 – 56 52 – 56 52 – 57 52 – 57 52 – 57 52 – 58 52 – 58 52 – 59 52 – 59 52 – 59
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5 17.6 17.7 17.8 17.9 17.10 17.11 Chapter	16 Automotive Fuel and Safety Systems (Onboard) Application. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. 17 Installation Requirements for ASME Tanks for LNG Application. General. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers. Piping. Container Instrumentation. Pressure Gauging and Control. 18	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57 52 - 57 52 - 57 52 - 58 52 - 59 52 - 59 52 - 59 52 - 59 52 - 59 52 - 59 52 - 59
16.1 16.2 16.3 16.4 Chapter 17.1 17.2 17.3 17.4 17.5 17.6 17.7 17.8 17.9 17.10 17.11 Chapter	16 Automotive Fuel and Safety Systems (Onboard) Application. General. General. CNG Engine Fuel Systems. LNG Engine Fuel Systems. Installation Requirements for ASME Tanks for LNG Application. General. Containers. Containers. Container Foundations and Supports. Container Installation. Automatic Product Retention Valves. Inspection. Testing and Purging of LNG Containers. Piping. Container Instrumentation. Pressure Gauging and Control.	52 - 45 52 - 45 52 - 45 52 - 45 52 - 52 52 - 56 52 - 56 52 - 56 52 - 57 52 - 57 52 - 57 52 - 57 52 - 58 52 - 58 52 - 59 52 -

2019 Edition

Annex A	Explanatory Material	52– 60
Annex B	Sample Ordinance Adopting NFPA 52	52– 66
Annex C	Pressure Relief Devices (PRDs)	52 – 67

Annex D	Informational References	52– 67
Index		52– 69

NFPA 52

Vehicular Natural Gas Fuel Systems Code

2019 Edition

IMPORTANT NOTE: This NFPA document is made available for use subject to important notices and legal disclaimers. These notices and disclaimers appear in all publications containing this document and may be found under the heading "Important Notices and Disclaimers Concerning NFPA Standards." They can also be viewed at www.nfpa.org/disclaimers or obtained on request from NFPA.

UPDATES, ALERTS, AND FUTURE EDITIONS: New editions of NFPA codes, standards, recommended practices, and guides (i.e., NFPA Standards) are released on scheduled revision cycles. This edition may be superseded by a later one, or it may be amended outside of its scheduled revision cycle through the issuance of Tentative Interim Amendments (TIAs). An official NFPA Standard at any point in time consists of the current edition of the document, together with all TIAs and Errata in effect. To verify that this document is the current edition or to determine if it has been amended by TIAs or Errata, please consult the National Fire Codes[®] Subscription Service or the "List of NFPA Codes & Standards" at www.nfpa.org/docinfo. In addition to TIAs and Errata, the document information pages also include the option to sign up for alerts for individual documents and to be involved in the development of the next edition.

NOTICE: An asterisk (*) following the number or letter designating a paragraph indicates that explanatory material on the paragraph can be found in Annex A.

A reference in brackets [] following a section or paragraph indicates material that has been extracted from another NFPA document. As an aid to the user, the complete title and edition of the source documents for extracts in mandatory sections of the document are given in Chapter 2 and those for extracts in informational sections are given in Annex D. Extracted text may be edited for consistency and style and may include the revision of internal paragraph references and other references as appropriate. Requests for interpretations or revisions of extracted text shall be sent to the technical committee responsible for the source document.

Information on referenced publications can be found in Chapter 2 and Annex D.

Chapter 1 Administration

1.1* Scope.

1.1.1 This code shall apply to the design, installation, operation, and maintenance of compressed natural gas (CNG) and liquefied natural gas (LNG) engine fuel systems on vehicles of all types and for fueling vehicle (dispensing) systems and facilities, and associated storage, including the following:

- (1) Original equipment manufacturers (OEMs)
- (2) Final-stage vehicle integrator/manufacturer (FSVIM)
- (3) Vehicle fueling (dispensing) systems

1.1.2 This code shall apply to the design, installation, operation, and maintenance of LNG engine fuel systems on vehicles of all types, to their associated fueling (dispensing) facilities, and to LNG to CNG facilities with LNG storage in ASME containers of 100,000 gal (379 m^3) or less.

1.1.3 This code shall not apply to those aspects of vehicles and fuel supply containers that are covered by federal motor vehicle safety standards (FMVSSs).

1.1.4 This code shall include marine, highway, rail, off-road, and industrial vehicles.

1.1.5 Where conflicts occur between provisions of this code and referenced codes and standards, the provisions of this code shall apply.

1.1.6 Where, in any specific case, different sections of this code specify different materials, methods, or other requirements, the most restrictive shall govern.

1.1.7 Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable.

1.1.8 Manufacturer specifications shall equal or surpass the applicable requirements of this code.

1.2 Purpose. The purpose of this code shall be to provide fundamental safeguards against fire and explosion hazards associated with compressed natural gas (CNG) and liquefied natural gas (LNG) engine fuel systems on vehicles of all types and for refueling stations and associated storage.

1.3 Retroactivity. The provisions of this code reflect a consensus of what is necessary to provide an acceptable degree of protection from the hazards addressed in this code at the time the code was issued.

1.3.1 Unless otherwise specified, the provisions of this code are not intended to require upgrading facilities, equipment, structures, or installations that existed or were approved for construction or installation prior to the effective date of the code. Where specified, the provisions of this code shall be retroactive.

1.3.2 In those cases where the authority having jurisdiction determines that the existing situation presents an unacceptable degree of risk, the authority having jurisdiction shall be permitted to apply retroactively any portions of this code deemed appropriate.

1.3.3 The retroactive requirements of this code shall be permitted to be modified if their application clearly would be impractical in the judgment of the authority having jurisdiction, and only where a reasonable degree of safety is provided and is clearly evident.

1.4 Alternate Provisions. Site conditions, advancements in technology, and improvements in system design and equipment shall be permitted to allow for equipment fabrication methods, component design requirements, and installation and operating practices that differ from those specified in this code.

1.4.1 Such deviations or improvements shall be permitted to provide equivalent safety and compatible operation that meet the intent of this code.

1.4.2 Such deviations shall be permitted where the authority having jurisdiction has seen evidence that a special investigation of all factors has been made and, based on sound experience and engineering judgment, has concluded that the proposed deviations meet the intent of this code.

Shaded text = Revisions. Δ = Text deletions and figure/table revisions. • = Section deletions. N = New material.